

CONTAMINANT GROUP* DATA REJECTION and MONITORING TRIGGERS

Contaminant Group	When BDL Reported, REJECT DATA if:	Frequency & Trigger when Sample Results > BDL
VOC	lab MDL > RDL	Quarterly, if Sample Result > RDL
SOC	lab MDL > ½ MCL	Quarterly, if Sample Result > RDL
Inorganics	lab MDL > MCL	Quarterly, if Sample Result > MCL
Secondary	lab MDL > MCL	No Trigger, remain on Triennial
Radiological	lab MDL > RDL	Quarterly, if Sample Result > MCL Triennial, if Sample Result > ½ MCL Every 6 yrs, if Sample Result > RDL Every 9 yrs, if Sample Result is BDL

* Table does **NOT** address treatment technique violations or acute contaminants, which includes nitrate, fecal coliform, ecoli, and chlorine dioxide.